

Managing the distribution grid: what's the limit?


21/11/2018

Lisa Calearo, Research Assistant

Center for Electric Power and Energy

DTU Risø Campus

DTU Electrical Engineering
Department of Electrical Engineering



- Introduction
- Study cases – LV grids
- Electric vehicle (EV) charging pattern model
- Technical analysis and results
- Economic analysis and results
- Conclusions and future work


The electric vehicle (EV) market is growing

DSO concern regarding grid operation:



- Loading issues
- Voltage issues

How can EVs be actively integrated in the electrical power distribution network maximizing the benefits for system, aggregator and user?






Study cases: LV grids



Based on the island consumption, Tejn and Rønne have characteristics, representative of the distribution grids in Bornholm.



Transformer/cable loading:

No transformer/cable overloading

Most loaded cables:



- Tejn: cable "St-10058"
- Rønne: cable "St-2332"

Voltage analysis:

No under-voltage values (<0.9 p.u.)


Most critical terminals:

- Tejn: terminal 4379
- Rønne: terminal 2352



Unbalanced grid

Tejn



Mean distribution: 42% phase a, 33% phase b, 25% phase c.


Rønne feeder has similar characteristics.

→ Assumed load: 40% in phase a, 30% in phase b,
30% in phase c.


EV charging pattern based on:

- historical driving characteristics of private conventional vehicles from Denmark

| Group | Distance x [km/day] |
|-------|--------------------------|
| G1 | $0 < x \leq 10$ |
| G2 | $10 < x \leq 20$ |
| G3 | $20 < x \leq 30$ |
| G4 | $30 < x \leq 40$ |
| G5 | $40 < x \leq 50$ |
| G6 | $50 < x \leq 70$ |
| G7 | $70 < x \leq 90$ |
| G8 | $90 < x \leq 110$ |
| G9 | $110 < x \leq 130$ |
| G10 | $130 < x \leq 150$ |



- home plug-in behavior of EVs from Japan





Evs: 40 kWh battery capacity

EV charging pattern result

- Single-phase chargers (3.7 kW): max 40-45% EVs charging together
- Three-phase chargers (11.1 kW): max 20-25% EVs charging together
- Higher rated power of the chargers → less EVs charging at same time, but higher peak consumption.

Example with 127 EVs (127 households in Tejn → 100% EV penetration):




What are the impacts of
different penetration levels of EVs on the
distribution networks of Bornholm?


Single-phase chargers

Transformer loading:

Tejn




Rønne




Voltage analysis:

Tejn: 4379



Rønne: 2352



100% EV penetration:

- single-phase chargers (Ch-1ph)
- three-phase chargers (Ch-3ph)

Transformer loading:

| | Transformer loading | | | |
|--------|---------------------|---------|----------|---------|
| | Tejn | | Rønne | |
| | mean [%] | max [%] | mean [%] | max [%] |
| Ch-1ph | 41.4 | 93.5 | 27.2 | 70.5 |
| Ch-3ph | 40.8 | 120 | 28.0 | 99.5 |

↑
9.25 h

Cable loading:


| | Cable loading | | | |
|--------|----------------|---------|----------------|---------|
| | Tejn: St-10058 | | Rønne: St-2338 | |
| | mean [%] | max [%] | mean [%] | max [%] |
| Ch-1ph | 36.0 | 91.6 | 27.4 | 79.6 |
| Ch-3ph | 34.7 | 116 | 28.3 | 102 |

↑
2 h


↑
0.2 h
(11 min)

Voltage analysis:

Tejn: 4379



Rønne: 2352



Which value can the EVs, as a flexible active component of the distribution system network, create for the system?
How should it be remunerated?


Voltage issues → EV active power modulation

Congestion issues:

→ ES1: DSO approach to transformer/cables overloading →
new upgraded transformer/cables


→ ES2: new approach to transformer/cables overloading →
EV support service: DSO is allowed by the EV owners to change the active power consumption

Economic scenario comparison



Replacement/upgrade transformer (400→630) and two cables:


Total investment: $CAPEX = 319500 \text{ DKK} + 69218 \text{ DKK} = 388718 \text{ DKK}$




ES2

| | |
|------------------------------|------------|
| Money available for 10 years | 97180 DKK |
| Money available per year | 9718.0 DKK |
| Money available per week | 186.9 DKK |

Transformer



Cables



| | |
|------------------------------|--------------|
| Scenario: | Ch-3ph |
| Moved energy during one week | 393 kWh |
| Maximum payment per kWh | 0.48 DKK/kWh |



~ 77 DKK/year per customer



- Tejn and Rønne, representative distribution grids of Bornholm, without EVs do not present congestion and voltage issues
- EV charging pattern model:
 - single-phase chargers → 40-45% EVs charge together
 - three-phase chargers → 20-25% EVs charge together
 - max active power consumption is higher with three-phase
- EVs connected with single-phase chargers:
 - under-voltage values, issues only with 100% penetration
 - solution: EV active power modulation

- EVs connected with three-phase chargers:
 - congestion issues with 100% penetration
 - solution: 1. components upgrade → investment: 388718 DKK
 - cost-effective with many and long overloading periods
 - 2. EV support service → available ~190 DKK/week
 - ~77 DKK/y per customer
 - preferable with few and short overloading periods
 - less need of EV support means higher remuneration

- Loading impact of V2G
- Plug-in rate at workplace
- Impact of fast chargers

Thanks for your attention!







Household consumption analysis

Analyzed weeks:

- Week 7: 12th to 18th February → normal winter week
- Week 9: 26th February to 4th March → the “Siberian cold”




The following analysis considers **week 9** assuming:

- $\cos(\Phi) = 0.966$ (derived from Ecogrid data)
- Load split on the 3 phases: 40%-30%-30% (derived from SGU data).

Simple approach example

- LV distribution grid with 400 kVA MV/LV transformer
- 110 householders
- EVs penetration levels: 25%-50%-75%-100% → 110 EVs with 100% penetration
- Plug-in time 17:00 for all EVs
- Average of 35 km/day




Fast chargers

Unknown consumption week 9.

Charging pattern is designed as follows:

- 10 pm - 4 am: Evs are used for frequency regulation
- 4 am - 6 am: EVs are charged → - average driven distance 80 km/day
- 6 am Evs have to be fully charged
- 6 am - 10 pm: EVs are driven → power equal to zero.



Ch-1ph: no control/P control



Transformer loading:

| | Transformer loading | | | |
|------------------|---------------------|------------|-------------|------------|
| | Tejn | | Rønne | |
| | mean [%] | max [%] | mean [%] | max [%] |
| <i>Ch-1ph</i> | 41.4 | 93.5 | 27.2 | 70.5 |
| <i>P control</i> | 40.8 | 88.6 | 27.0 | 68.8 |

Voltage analysis:

Tejn

Rønne



Scenario

Scenario

Ch-1ph: balanced/unbalanced

Transformer loading:


| | Tejn | Ronne |
|------------|------------|------------|
| | S_{\max} | S_{\max} |
| | [%] | [%] |
| Balanced | 93.4 | 70.5 |
| Unbalanced | 94.7 | 68.7 |

Cable loading:


| | Cable loading | | | | | |
|------------|----------------|------|----------------|------|----------------|------|
| | Tejn: St-10058 | | Tejn: St-10120 | | Rønne: St-2338 | |
| | mean | max | mean | max | mean | max |
| | [%] | [%] | [%] | [%] | [%] | [%] |
| Balanced | 36.0 | 91.6 | 24.5 | 68.0 | 27.4 | 79.6 |
| Unbalanced | 36.1 | 84.8 | 31.2 | 113 | 29.5 | 93.5 |

Voltage analysis:

Tejn



Rønne



Effect of the ToU tariffs: plug-in time all EVs at 20

EV owners perspective: 0.5 DKK/kWh less if charging after 20

→ Total savings per year approx. 310-550 DKK...

Transformer loading:


| | Transformer loading | | | |
|--------|---------------------|-------------|------------|-------------|
| | Tejn | | Ronne | |
| | max [%] | time [h] | max [%] | time [h] |
| Ch-1ph | 93.4 | 0 | 73 | 0 |
| Ch-3ph | 201 | 10.8 | 162 | 9.83 |

Cable loading:


| | Cable loading | | | |
|--------|----------------|-------------|----------------|-------------|
| | Tejn: St-10058 | | Ronne: St-2338 | |
| | max [%] | time [h] | max [%] | time [h] |
| Ch-1ph | 106 | 2 | 85.9 | 0 |
| Ch-3ph | 199 | 9.75 | 161 | 9.82 |

Voltage analysis:

Tejn



Rønne



...**DSO** perspective
→ Congestion,
low-voltage values